

Garfield Bay Water & Sewer District #82

Commercial Sewer Service Requirements

Recreational Vehicle Park: Sewer Service Requirements for RV Parks are based upon the combined flow rates of the numbers and types of facilities shown in the Flow Rate Table below.

All Other Commercial Enterprises: All other commercial enterprises are required to have a minimum of one basic service unit 263/ERU gallons per day (GPD) - plus expanded sewer service for the numbers and types of facilities shown in the Flow Rate Table.

Flow Rate Table

20 GPD for each bar/restaurant customer seat.
20 GPD for each employee in retail store.
40 GPD for each public restroom in a retail store, gas station or repair shop.
75 GPD for each recreational vehicle or boat dump station.
100 GPD for each public laundry facility washing machine.
100 GPD for each public shower stall in an RV park or marina.
40 GPD for each public toilet and urinal in an RV park or marina.
85 GPD for each RV space having a sewer inlet.
100 GPD for each rental cabin.

Note 1: Any recreational vehicle that occupies an RV space with a sewer connection 150 days or more in a calendar year is classed as a single-family residence (263 GPD).

Note 2: Any rental cabin occupied for 150 or more days in a calendar year is classed as a single-family residence (263 GPD).

NOTE: Please refer to the Uniform Plumbing Code and inquire at controlling agencies for the numbers and types of facilities required for a specific business.